

Puget Sound Gas Works

425-343-5566

PugetSoundGasWorks@Gmail.com

30326 36th Ave NW, Stanwood, Wa 98292

Gas Pipe Pressure Test Affidavit
For Cascade Natural Gas Company

Project Address: Major, Ross E
1705 - 11th St
Antarctic

This gas line was tested at 15 pounds pressure for twenty minutes to check for gas leaks.

Gauges were checked thoroughly so pressure will not be released.

This gas line was soap tested to check for gas leaks.

By signature of the gas pipe mechanic, the gas leak test was completed and held test.

Gas Pipe Mechanic: [Signature] 7-31-17
Date

Pressure Test Date: 7-31-17