Puget Sound Gas Works

425-343-5566
PugetSoundGasWorks@Gmail.com
30326 36th Ave NW, Stanwood, Wa 98292

Gas Pipe Pressure Test Affidavit
For Cascade Natural Gas Company

Retire/replace gas meter

Project Address: Peterson, Kent
1805 11th St
Antacortis, Wa

_____ This gas line was tested at 15 pounds pressure for twenty minutes to check for gas leaks.

_____ Gauges were checked thouroughly so pressure will not be released.

__✓__ This gas line was soap tested to check for gas leaks.

By signature of the gas pipe mechanic, the gas leak test was completed and held test.

Gas Pipe Mechanic: Dalton Nichols 8/1/17
Date

Pressure Test Date: _____