

Puget Sound Gas Works

425-343-5566

PugetSoundGasWorks@Gmail.com

30326 36th Ave NW, Stanwood, Wa 98292

Gas Pipe Pressure Test Affidavit  
For Cascade Natural Gas Company

retire/replace  
gas meter

Project Address:

Merritt, Cindy

1614 12th St

Anacortes, Wa

This gas line was tested at 15 pounds pressure for twenty minutes to check for gas leaks.

Gauges were checked thoroughly so pressure will not be released.

This gas line was soap tested to check for gas leaks.

By signature of the gas pipe mechanic, the gas leak test was completed and held test.

Gas Pipe Mechanic:

*John Olson*

8-1-17

Date

~~Pressure Test Date:~~

Bubble

8-1-17