



ANACORTES PUBLIC WORKS DEPARTMENT

Jim Baldwin, Public Works Inspector
P.O. BOX 547, ANACORTES, WA 98221
E-MAIL: jimb@cityofanacortes.org

Cell: 360.661.3547
Office/Inspections: 360.299.1972
FAX(360) 293-1938

Memo

Date: February 6, 2008

To: Roy Christiansen, Builder

From: Jim Baldwin

Subject: Correction Notice – 2017 29th Place

cc: Eric Shjarback, Steven Lange, Don Measamer

A site inspection was performed on your building site at 2017 29th Place on February 4, 2008. Below are the following items that need immediate attention.

1. Stabilize all exposed areas using DOE approved BMP's.
2. Remove all construction debris from the Public Right-of-Way
3. Install a DOE approved construction entrance.
4. Remove concrete, construction debris and rock larger than 2-inches from the area between the curb and sidewalk.
5. Install to sidewalk grade, compacted topsoil in the area between the curb and sidewalk.

If you have any questions regarding this Correction Memo or need an inspection, please contact me at 360.299.1972. For your information, inspections need a minimum of 24-hours notice for proper scheduling.

Thank you for your attention to this matter.

Jim Baldwin
Public Works Inspector
