



**CITY OF ANACORTES
WASHINGTON**

BUILDING DEPARTMENT

CERTIFICATE OF OCCUPANCY

This is to certify that the (Description of Building or Structure):

Single Family Residence

Located At: 1804 39th Court
STREET & NUMBER

Owner: Strandberg Construction

Constructed By: Owner
OWNER OR CONTRACTOR

Bldg. Permit#: COM2000-00103

Date Issued: 6/26/00

Occ. Group: R3 Use Zone: R2

Has Been Inspected And Occupancy Is Hereby Authorized.

This 5th Day of December 20 00

[Signature]
AUTHORIZING OFFICIAL

SEE REVERSE SIDE FOR SPECIAL REQUIREMENTS.

FINAL INSPECTION CHECKLIST

Inspection Date: 11/30/00

Address: 1804 ~~S~~ 39th Court

Permit No. ^{Com} 2000-00103 Date: 6-~~24~~ 00 Zone: _____

Owners Name: Strandberg Construction

Owners Address: PO Box 319 Anacortes

Occupancy Group: R-3 Construction Type: V-N

Variances: OK Safety Glass: OK

Sewer Fee Paid: OK Hand Rails: OK

Sewer Inspected: OK Guard Rails: OK

WSEC Compliance: OK Traps: OK

Attic Access: OK Wood Stove: don't have one

Smoke Detectors: OK Water Pressure: OK 80

T&P Drain: need 90° fittings House Numbers: OK

Insulation Cert: will send to off Site Drainage: OK

Radon Test Kit: not needed Curb Cut: OK

Garage House Door: OK Crawl Space Insul: OK

Bedroom Windows: OK Crawl Space Access: OK need cover

Water Heater Strap: OK Vapor Barrier: OK

D.W. Air Gap: OK Water Meter Box: OK

Auto Garage Door: OK Outside Caulking: OK

Exterior Decks/Landings: OK

Exh. Duct/Dryer Vent Dampers: OK