Public Works
Engineering and Development Services

Pressure Test Inspection

■ Water ☐ Sewer ☐ Storm

Project Name	Anacortes Sleep Clinic 2031 10 Ave	Comments:	225 PSI / 2 hrs - 5 PSI MAX LOSS
Project Number	08-003-DCM		Allowed
Inspector Name	J. M. Baldwin		Two Fire Lines - 1 - 127'
Contractor Name	Trico Construction		2 - 67'

	Structures		Time						
Date	From	To	Start	Finish	Pressure	Drop	Pass	Fail	Corrective Action – Notes
4-29-08	Valve 22nd St	Standpipe	10:00 AM	12:00PM	225	∅	■	☐	Length of Run - 127'
	[redacted]	[redacted]					☐	☐	
4-30-08	Standpipe	Standpipe	12:30 PM	2:30 PM	225	∅	■	☐	Length of Run - 67'
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	
							☐	☐	